



Lake County, Florida
Office of Procurement Services

ADDENDUM #4

Invitation to Bid 06-055

Bid Title: Lake County Detention Center Roof Replacement

Date: 5/12/06

This addendum is being issued to make the following clarifications to the bidding documents. The information in this addendum modifies and changes the original bidding documents and takes precedence over the original documents. Receipt of this addendum shall be acknowledged by the bidder by initialing and dating the appropriate line. Failure to acknowledge this addendum may preclude consideration of the bid proposal for award.

In response to JCE Services fax inquiring about the lightning protection system.

Remove the existing lightning protection system to accommodate installation of the roof. After the roofing system is installed, reinstall the lightning protection system to comply with NFPA780 and UL96. Once the installation is complete, Lake County will have the lightning protection systems inspected by an inspection contractor for code compliance and certification.”

If you have any questions concerning this Addendum or the Invitation to Bid, please contact Donna Thielhart, Contracting Officer 352.343.9525, dthielhart@co.lake.fl.us, as soon as possible before the closing date.

Firm or Individual's Name: _____

Date: _____

Signature: _____ Title: _____

Typed/Printed Name: _____